

Swedish Technical Approval

SC0385-16

and decision on production control, in accordance with chapter 8, 22 and 23 §§ Planning- and Building Act (2010:900), PBL

Floor gully, Purus S-serie Minimax

Holder

Purus AB, Södra Dragongatan 15, 271 39 Ystad, Sweden.
Organisation number: 559007-0032.
Tel: 010-41 44 900, fax: 010-41 44 996.
E-mail: info@purus.se internet: www.purus.se

Product

Floor gully S-serie Minimax is designed with side outlet DN 50. Body and water trap (Purus NOOD) are made of plastic (PP). The gully is delivered with Purus stainless steel clamping ring with screws. The gully is intended for grating in stainless steel (Ø174 mm) with loading strength class K3, RSK no. 712 95 07.

Intended use

Floor gully intended for waste water and for installation in concrete floor constructions with surface of ceramic tiles or vinyl sheet flooring.

Trade name

Purus S-serie Minimax, RSK no. 711 04 06.

Approval

The products satisfy the requirements set forth in chapter 8, 4 § 3 PBL, in respect to and under conditions stated in this certificate, and are therefore approved in accordance with the provisions of the following sections of Boverket Building Regulations (BBR):

Waste water installations	6:641, 1:st paragraph and last sentence in 2:nd paragraph
Design	6:644, 1:st sentence and 2:nd paragraph

Associated documents

Installation instruction Purus S-serie 22206-201605.

Control

The factory production control (FPC) is monitored by an independent inspection body. Control agreement: 351. Inspection body: DTI Danish Technological Institute.

Control continue

When the building proprietor performs inspection at the building site, he shall check the markings to ensure that the correct products have been supplied and that they are used in accordance with the requirements stated in the approval and the associated documents. He must also check that the product is accompanied by a manufacturing assurance, which certifies that the product has been manufactured in accordance with the documents on which this approval is based.

Manufacturer

Production control includes the following site:
BLS Industries AB, Södra Dragongatan 15, 271 39 Ystad, Sweden.

Marking

The products are to be marked at the factory.
The marking consists of a text on every product and packing supplied and includes:

On product and packing:

Distributor	PURUS
Product name	S-serie Minimax
Product code/RSK-no.	711 04 06
Boverket's registered trademark	⚡
Certification body and accreditation number	SP Certifiering 1002
Inspection body	DTI

Product is also marked with:

Consecutive manufacture year/month of production	year/month
Approval number	SC0385-16

Basis for approval

Report 684426 from DTI, Danish Technological Institute.

Comments

Installation instructions shall be delivered in each package.
Floor gullies are approved according to standard SS-EN1253-1. The function of the partially mechanical water trap has been deemed to correspond to a trap depth of 50 mm, the removable water trap needs to be cleaned regularly.

Purus S-serie Minimax has flow capacity 0,48 l/s.



Period of validity

This approval is valid until 2021-06-16.

The validity of this approval expires when the characteristics included in this approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.

SP Technical Research Institute of Sweden Certification

Ingvar Pettersson

Marcus Tillman