

and decision on production control, in accordance with chapter 8, 22 and 23 §§ Planning- and Building Act (2010:900), PBL

Floor gully, Purus Mini Brage 50, Mini Brage 110 and Mini Oden 50

Holder

Purus AB, Södra Dragongatan 15, 271 39 Ystad, Sweden.
Organisation number: 559007-0032.
Tel: 010-41 44 900, fax: 010-41 44 996.
E-mail: info@purus.se internet: www.purus.se

Product

Floor gully Purus Mini Brage 50, Mini Brage 110 and Mini Oden are made of PP. Mini Brage 50 is designed with vertical outlet and Mini Oden 50 is designed with side outlet with Ø50 mm. Mini Brage 110 is designed with vertical outlet in Ø110 mm. All gullies are delivered with Purus Flex Neptun water trap, Purus KL 130 automatic clamping ring and grating (Ø130 mm). Gullies fulfill requirement for loading strength class K3.

Intended use

Floor gully intended for waste water and for installation in timber or concrete floor constructions with surface of ceramic tiles or vinyl sheet flooring.

Trade name

Purus Mini Brage 50, Mini Brage 110 och Mini Oden 50.

Approval

The products satisfy the requirements set forth in chapter 8, 4 § 3 PBL, in respect to and under conditions stated in this certificate, and are therefore approved in accordance with the provisions of the following sections of Boverket Building Regulations (BBR):

Waste water installations	6:641, 1:st paragraph and last sentence in 2:nd paragraph
Design	6:644, 1:st sentence and 2:nd paragraph

Associated documents

Installation instruction Purus floor gullies 130, dated 2012-01-16.

Control

The factory production control (FPC) is monitored by an independent inspection body.
Control agreement: 351. Inspection body: DTI Danish Technological Institute.

When the building proprietor performs inspection at the building site, he shall check the markings to ensure that the correct products have been supplied and that they are used in accordance with the requirements stated in the approval and the associated documents. He must also check that the product is accompanied by a manufacturing assurance, which certifies that the product has been manufactured in accordance with the documents on which this approval is based.

Manufacturer

Production control includes the following site:
BLS Industries AB, Södra Dragongatan 15, 271 39 Ystad, Sweden.

Marking

The products are to be marked at the factory.
The marking consists of a text on every product and packing supplied and includes:

On product and packing:

Distributor	PURUS
Product name	Trade name
Product code/RSK-no.	number
Boverket's registered trademark	†
Certification body and accreditation number	SP Certifiering 1002
Inspection body	DTI

Product is also marked with:

Consecutive manufacture year/month of production	year/month
Approval number	0077/00

Basis for approval

Report 270-9-0831A-55, 270-9-0831B-55 and 270-9-0831C-55 from DTI.

Comments

Installation instructions shall be delivered in each package.

Those floor gullies are approved according to standard SS-EN1253-1:2003, with the exception of Brage Mini 110 that has a flow capacity of 0.9 l/s.

Mini Brage 50 has flow capacity 1,3 l/s.

Mini Oden 50 has flow capacity 0,8 l/s.

The removable water trap needs to be cleaned regularly.

This approval supersedes the previous approval with the same number dated 03 March 2011.



Period of validity

This approval is valid until 9 December 2020.

The validity of this approval expires when the characteristics included in this approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.

SP Technical Research Institute of Sweden Certification

Ingvar Pettersson

Marcus Tillman